



GOLDEN GATE FIRE PROTECTION DISTRICT FEE SCHEDULE 2024

*Comprehensive Planning Review Partnership	\$300/per project year
Residential Rezone and Subdivision Review	\$100 per lot
Secondary Driveway Permit Inspection	\$150/ per review
Burn Permit	Suggested Donation of \$50
Will-Serve Letter	Suggested Donation of \$50
Cistern Re-inspection	Suggested Donation of \$100
Defensible Space Inspection	Suggested Donation of \$75
Non-Resident Response	Suggested Donation of \$200

*Comprehensive planning review partnership Includes: Initial will-serve letter, Initial residential sprinkler and fire alarm plan review, initial defensible space review, initial cistern inspection, initial driveway review. This flat fee is assessed annually until the project is completed; no additional fees shall be assessed during the time a residence is under a planning review partnership regardless of re-inspection requirements. The purpose of this partnership is to ensure safe building practices and code compliance within the Golden Gate Fire Protection District.

Application: The plan review application shall include all plans, specification sheets, application form and the comprehensive planning review fee. The application form and fee shall be submitted, paid and approved PRIOR to work being started. The AHJ reserves the right to conduct an investigation and assess a Planning review partnership fee, as outlined in the Permit Fee Schedule if the above procedure is not followed.

Two complete sets of drawings are required along with technical specification sheets for all construction applications.

Approval Process:

Following the fire department review, a letter may be sent to the applicant indicating items that require corrections. One approved set of plans or drawings will be returned to the applicant with the permit. These items shall be kept on site during construction. The applicant shall be responsible for corrections before receiving final acceptance and discharge from the partnership program.

Components:

All fire protection and life safety equipment shall be UL or FM listed and approved by the AHJ.